



PROVIDE GROSS SLOPE: 1/5% MIN.; 2% MAX.

PROVIDE EXPANSION JOINTS @ 30'-0" MAX

PROVIDE TOOLED OR SAWED JOINTS @ 6'-0" O.C. MAX

WHERE PERMITTED BY SITE LAYOUT, SEPERATE SIDEWALK FROM CURB WITH LANDSCAPE/GRASS FOR PEDESTRIAN SAFETY.

SECTION

## INTEGRAL CONCRETE SIDEWALK AND CURB